



Imagination is more important than knowledge

- Albert Einstein

REWARDING EFFICIENCY: Clean Energy *via* resilient and sustainable Combined Heating & Power (CHP) system

Combined Heat & Power (CHP) options for _____

Cut cost of energy & water
Cut Greenhouse Gas Emissions (GHG)
Increase resiliency = (redundancy, availability)

Suresh Jambunathan

630-335-4544

suresh.jambunathan@enwadev.com



Inside-the-fence CHP project Executive Summary

_____ site offers an economically attractive (i.e. *financeable*), technically robust, environmentally friendly, load-scalable & supply-resilient opportunity for an efficient natural gas Combined Heat & Power (CHP) project.

Options to improve Return on Invested Capital (ROIC) include the 10% Investment Tax Credit (ITC), avoided/reduced investment on thermal & electrical infrastructure, 3rd party financing, project leverage etc... The project also creates an option for C-credits *plus* potential to reduce site water intensity (not in this scope).

A Project Execution Plan (PEP) will layout the critical path to tighten an anticipated 10-to-16 months schedule from Limited Notice to Proceed (LNTP) to Commercial Operations Date (COD).

Project risks can be mitigated with a robust PEP and early milestones should include co-ordination with local utility, soliciting community support & engagement with local permitting authorities.

_____ can significantly boost CHP project economics by selling heat (i.e. hot water) to Industrial Facility (IF) on the north. External energy sale demonstrates ingenuity & community spirit, increases sustainability *and* supply side resiliency of the IF.

Screen shot of site



Close up Screen shot of CHP location

Sell CHP waste heat to Industrial Facility;
boost CHP efficiency *and* secure high-margin incremental revenue

Install CHP at _____ plant



BASE CASE economic summary: 10-year CHP project horizon

COMMON INPUT's	UNIT	VALUE	COMMENT
FUTURE baseline site Load	% load increase	50%	2020 base
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price	c/KWh	7.6	site data
CHP project financing			
CHP Project horizon (max 20-yrs)	years	10	
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	12	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	assumed

Sized & modeled 3-alternate CHP configurations

CHP saves site energy expense (power + fuel), reduces emissions and increases supply side resiliency.

Comparable emissions reductions & efficiencies across all CHP configurations

- 2 x Reciprocating Engine CHP has lowest first cost.
- 1 x Gas Turbine CHP has highest lifetime savings.

No conflict between wallet & conscience !

		NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover		-	JMS420	OPRA16	Centaur40
CHP Configuration		Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)		-	1.1	0.8	1.2
***Site Energy Expense					
Year 1	\$MM	\$3.0	\$2.2	\$2.2	\$2.0
Year 10	\$MM	\$31	\$24	\$23	\$20
Cum. %redn. 10 yrs	% reduction	0%	-22%	-26%	-34%
Emissions					
From grid power	mt CO ₂	22,184	4,641	1,652	3,246
From fuel to Blrs	mt CO ₂	10,264	6,987	360	699
From fuel to CHP	mt CO ₂	-	11,004	21,434	19,395
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446	23,340
Emissions reduction	% change	0%	-30%	-28%	-28%
CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	61.3%	60.4%	63.4%
Thermal Utilization	%	-	63%	64%	77%
Annual Energy supply to site					
Fuel to Blrs	MMBtu	193,164	131,494	6,769	13,161
Fuel to CHP	MMBtu	-	207,094	403,375	365,005
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144	378,166
Elec. From grid	MWh	28,093	5,877	2,093	4,110
Elec. From CHP	MWh	-	22,215	26,000	23,982
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093	28,093

NOTES:
*Pjt Inv. w/10%ITC = CHP only investment less 10% ITC. Excludes credit for avoided CapEx for blrs, elec. Infra. Etc..
** Equity MOI = (Cumulative project cash / Equity only investment)
***power + fuel + O&M + Debt. Service



CHP Operations & Maintenance proforma: vendor quotes + reasonable assumptions

OPERATIONS & MAINTENANCE EXPENSE			CHP as 2 x JMS420	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042			
				0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20			
INFLATION																											
Equipment / Maintenance assets			%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%			
Labor /staff			%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%			
A	# MAINTENANCE	\$/fired hour/unit	Maint/yr																								
	Gas-Turbine	-	\$0.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0			
	RE-HWSS	-	\$0.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0			
	Gas Compressor	-	\$0.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0			
	Reciprocating Engine	\$27.68	\$460,706	\$460,706	\$467,617	\$474,631	\$481,750	\$488,976	\$496,311	\$503,756	\$511,312	\$518,982	\$526,767	\$534,668	\$542,688	\$550,828	\$559,091	\$567,477	\$575,989	\$584,629	\$593,399	\$602,300	\$611,334	\$620,504			
	Reciprocating Engine MAJOR OVERHAUL at 60000 Optg Hrs	-	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0			
	RE-HWSS/HRU	-	\$15,000	\$15,000	\$15,225	\$15,453	\$15,685	\$15,920	\$16,159	\$16,402	\$16,648	\$16,897	\$17,151	\$17,408	\$17,669	\$17,934	\$18,203	\$18,476	\$18,753	\$19,035	\$19,320	\$19,610	\$19,904	\$20,203			
	Other	-	\$5,000	\$5,075	\$5,151	\$5,228	\$5,307	\$5,386	\$5,467	\$5,549	\$5,632	\$5,717	\$5,803	\$5,890	\$5,978	\$6,068	\$6,159	\$6,251	\$6,345	\$6,440	\$6,537	\$6,635	\$6,734	\$6,833			
	SUB-TOTAL # MAINTENANCE			\$	\$480,706	\$487,937	\$495,235	\$502,664	\$510,204	\$517,857	\$525,625	\$533,509	\$541,502	\$549,634	\$557,879	\$566,247	\$574,741	\$583,362	\$592,112	\$600,994	\$1,724,178	\$619,159	\$628,446	\$637,873	\$647,441		
	B	# CONSUMABLES																									
Emissions Control System (ECS) chemicals		\$20,000	\$	\$20,000	\$20,300	\$20,605	\$20,914	\$21,227	\$21,546	\$21,869	\$22,197	\$22,530	\$22,868	\$23,211	\$23,559	\$23,912	\$24,271	\$24,635	\$25,005	\$25,380	\$25,760	\$26,147	\$26,539	\$26,937			
Other - misc		\$10,000	\$	\$10,000	\$10,150	\$10,302	\$10,457	\$10,614	\$10,773	\$10,934	\$11,098	\$11,265	\$11,434	\$11,605	\$11,779	\$11,956	\$12,136	\$12,318	\$12,502	\$12,690	\$12,880	\$13,073	\$13,270	\$13,469			
SUB-TOTAL # CONSUMABLES			\$30,000	\$30,450	\$30,907	\$31,370	\$31,841	\$32,319	\$32,803	\$33,295	\$33,795	\$34,302	\$34,816	\$35,338	\$35,869	\$36,407	\$36,953	\$37,507	\$38,070	\$38,641	\$39,220	\$39,809	\$40,406	\$41,006			
C	# OPERATIONS	% reqd.	\$/hr	UNIT \$/yr	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042		
					0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
	1	Energy systems manager	25%	860	124,800	\$	\$31,200	\$31,980	\$32,780	\$33,599	\$34,439	\$35,300	\$36,182	\$37,087	\$38,014	\$38,965	\$39,939	\$40,937	\$41,961	\$43,010	\$44,085	\$45,187	\$46,317	\$47,474	\$48,661	\$49,878	\$51,125
	3	Operators	10%	840	83,200	\$	\$24,960	\$25,584	\$26,224	\$26,879	\$27,551	\$28,240	\$28,946	\$29,670	\$30,411	\$31,172	\$31,951	\$32,750	\$33,568	\$34,408	\$35,268	\$36,150	\$37,053	\$37,980	\$38,929	\$39,902	\$40,900
	3	Maintenance	10%	850	104,000	\$	\$31,200	\$31,980	\$32,780	\$33,599	\$34,439	\$35,300	\$36,182	\$37,087	\$38,014	\$38,965	\$39,939	\$40,937	\$41,961	\$43,010	\$44,085	\$45,187	\$46,317	\$47,474	\$48,661	\$49,878	\$51,125
	1	Admin. Asst.	25%	825	52,000	\$	\$13,000	\$13,325	\$13,658	\$14,000	\$14,350	\$14,708	\$15,076	\$15,453	\$15,839	\$16,235	\$16,641	\$17,057	\$17,484	\$17,921	\$18,369	\$18,828	\$19,299	\$19,781	\$20,276	\$20,782	\$21,302
	0	other	0%	820	41,600	\$	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
	SUB-TOTAL # OPERATIONS			\$	\$100,360	\$102,869	\$105,441	\$108,077	\$110,779	\$113,548	\$116,387	\$119,297	\$122,279	\$125,336	\$128,469	\$131,681	\$134,973	\$138,347	\$141,806	\$145,351	\$148,985	\$152,710	\$156,527	\$160,441	\$164,452		
	A+B+C	TOTAL O&M	\$	\$611,066	\$621,236	\$631,583	\$642,111	\$652,823	\$663,723	\$674,815	\$686,101	\$697,646	\$709,472	\$721,644	\$734,267	\$747,345	\$759,882	\$772,871	\$786,321	\$798,852	\$1,911,233	\$810,509	\$824,194	\$838,122	\$852,298		

OPERATIONS & MAINTENANCE EXPENSE			CHP as 1 x Centaur40	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042		
				0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
INFLATION																										
Equipment / Maintenance assets			%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%		
Labor /staff			%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%		
A	# MAINTENANCE	\$/fired hour/unit	Maint/yr																							
	Gas Turbine	\$32.00	\$266,304	\$	\$266,304	\$270,299	\$274,353	\$278,468	\$282,645	\$286,885	\$291,188	\$295,556	\$299,989	\$304,489	\$309,057	\$313,693	\$318,398	\$323,174	\$328,021	\$332,942	\$337,936	\$343,005	\$348,150	\$353,372	\$358,673	
	GT-HWSS	-	\$15,000	\$	\$15,000	\$15,225	\$15,453	\$15,685	\$15,920	\$16,159	\$16,402	\$16,648	\$16,897	\$17,151	\$17,408	\$17,669	\$17,934	\$18,203	\$18,476	\$18,753	\$19,035	\$19,320	\$19,610	\$19,904	\$20,203	
	Gas Compressor	-	\$5,000	\$	\$5,000	\$5,075	\$5,151	\$5,228	\$5,307	\$5,386	\$5,467	\$5,549	\$5,632	\$5,717	\$5,803	\$5,890	\$5,978	\$6,068	\$6,159	\$6,251	\$6,345	\$6,440	\$6,537	\$6,635	\$6,734	
	Reciprocating Engine	-	\$0.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
	Gas Turbine MAJOR OVERHAUL at 35000 Optg Hrs	-	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
	RE-HWSS/HRU	-	\$0.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
	Other	-	\$5,000	\$	\$5,000	\$5,075	\$5,151	\$5,228	\$5,307	\$5,386	\$5,467	\$5,549	\$5,632	\$5,717	\$5,803	\$5,890	\$5,978	\$6,068	\$6,159	\$6,251	\$6,345	\$6,440	\$6,537	\$6,635	\$6,734	
	SUB-TOTAL # MAINTENANCE			\$	\$291,304	\$295,674	\$300,109	\$304,610	\$309,179	\$313,817	\$318,524	\$323,302	\$328,152	\$333,074	\$338,070	\$343,141	\$348,288	\$353,513	\$358,815	\$364,198	\$369,661	\$375,205	\$380,834	\$386,546	\$392,344	
	B	# CONSUMABLES																								
Emissions Control System (ECS) chemicals		\$20,000	\$	\$20,000	\$20,300	\$20,605	\$20,914	\$21,227	\$21,546	\$21,869	\$22,197	\$22,530	\$22,868	\$23,211	\$23,559	\$23,912	\$24,271	\$24,635	\$25,005	\$25,380	\$25,760	\$26,147	\$26,539	\$26,937		
Other - misc		\$10,000	\$	\$10,000	\$10,150	\$10,302	\$10,457	\$10,614	\$10,773	\$10,934	\$11,098	\$11,265	\$11,434	\$11,605	\$11,779	\$11,956	\$12,136	\$12,318	\$12,502	\$12,690	\$12,880	\$13,073	\$13,270	\$13,469		
SUB-TOTAL # CONSUMABLES			\$30,000	\$	\$30,450	\$30,907	\$31,370	\$31,841	\$32,319	\$32,803	\$33,295	\$33,795	\$34,302	\$34,816	\$35,338	\$35,869	\$36,407	\$36,953	\$37,507	\$38,070	\$38,641	\$39,220	\$39,809	\$40,406		
C	# OPERATIONS	% reqd.	\$/hr	UNIT \$/yr	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	
					0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
1	Energy systems manager	25%	860	124,800	\$	\$31,200	\$31,980	\$32,780	\$33,599	\$34,439	\$35,300	\$36,182	\$37,087	\$38,014	\$38,965	\$39,939	\$40,937	\$41,961	\$43,010	\$44,085	\$45,187	\$46,317	\$47,474	\$48,661	\$49,878	\$51,125
3	Operators	10%	840	83,200	\$	\$24,960	\$25,584	\$26,224	\$26,879	\$27,551	\$28,240	\$28,946	\$29,670	\$30,411	\$31,172	\$31,951	\$32,750	\$33,568	\$34,408	\$35,268	\$36,150	\$37,053	\$37,980	\$38,929	\$39,902	\$40,900
3	Maintenance	10%	850	104,000	\$	\$31,200	\$31,980	\$32,780	\$33,599	\$34,439	\$35,300	\$36,182	\$37,087	\$38,014	\$38,965	\$39,939	\$40,937	\$41,961	\$43,010	\$44,085	\$45,187	\$46,317	\$47,474	\$48,661	\$49,878	\$51,125
1	Admin. Asst.	25%	825	52,000	\$	\$13,000	\$13,325	\$13,658	\$14,000	\$14,350	\$14,708	\$15,076	\$15,453	\$15,839	\$16,235	\$16,641	\$17,057	\$17,484	\$17,921	\$18,369	\$18,828	\$19,299	\$19,781	\$20,276	\$20,782	\$21,302
0	other	0%	820	41,600	\$	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
SUB-TOTAL # OPERATIONS			\$	\$100,360	\$102,869	\$105,441	\$108,077	\$110,779	\$113,548	\$116,387	\$119,297	\$122,279	\$125,336	\$128,469	\$131,681	\$134,973	\$138,347	\$141,806	\$145,351	\$148,985	\$152,710	\$156,527	\$160,441	\$164,452		
A+B+C	TOTAL O&M	\$	\$421,664	\$428,993	\$436,456	\$444,057	\$451,799	\$459,684	\$467,715	\$475,894	\$484,225	\$492,712	\$501,356	\$510,161	\$519,130	\$528,267	\$537,574	\$547,056	\$556,715	\$566,556	\$576,581	\$586,795	\$597,201			

OPERATIONS & MAINTENANCE EXPENSE		CHP as 2 x OPRA16	2022	2023	2024	2025	2026	2027	2028</
----------------------------------	--	-------------------	------	------	------	------	------	------	--------







METRICS for RE-CHP																										
w/RE-CHP	Full Load Optix Hrs		8,322																							
w/RE-CHP	CHP peak power PEAK MW		2,486																							
w/RE-CHP	CHP electricity supplied MWh		22,215																							
Avg. CHP thermal Energy sold MMBtu/Hr			6.2																							
Annual CHP thermal energy sold MMBtu			51,186																							
Avg. Fuel to CHP Engines HHV MMBtu/Hr			Reconcile																							
Annual Fuel to CHP Engines HHV MMBtu			207,094																							
RE-CHP: Fraction of Host load supplied																										
% Electricity from RE-CHP			79.1%																							
% Energy from RE-CHP			31.9%																							
w/RE-CHP	CHP Efficiency % HHV		61%																							
w/RE-CHP	CHP Heat Rate HHV MMBtu/kWh		6.8																							
w/RE-CHP	CHP Thermal Energy Rate HHV MMBtu/MMBtuHrs		2.9																							
Operations & Maintenance (O&M) \$/MWh			\$0.61																							
Total O&M Cost \$/MWh			\$0.76																							
RE-CHP Fuel Cost of Power \$/MWh			\$18.8																							
Fuel Cost of Thermal Energy \$/MMBtuHrs			\$8.2																							
w/RE-CHP	Peak Grid power MW		2.1																							
w/RE-CHP	Grid electricity MW		5,877																							
w/RE-CHP	Grid electricity \$/MWh		\$0.45																							
w/RE-CHP	CHP Standby Charges \$/MWh		\$0.04																							
w/RE-CHP	Total cost of Grid power \$/MWh		\$0.49																							
Package Boiler Thermal Energy																										
w/RE-CHP	Thermal energy delivered MMBtuHrs		109,140																							
w/RE-CHP	Natural gas to Boiler HHV MMBtu		131,494																							
w/RE-CHP	Natural gas to Boiler \$/MMBtu		\$0.36																							
w/RE-CHP	TOTAL Fuel Burned (CHP+Blr) HHV MMBtu		338,587																							
CO2 EMISSIONS																										
w/RE-CHP	CO2 from grid power mt CO2		3,718																							
w/RE-CHP	CO2 from fuel to boilers mt CO2		6,815																							
w/RE-CHP	Total CO2 emissions mt CO2		10,533																							
BASE CASE - NO CHP			0																							
NO CHP	Cost of Grid Power \$/MWh		\$2.15																							
NO CHP	Cost of Blr natural gas \$/MMBtu		\$0.6																							
NO CHP	Cost of Blr O&M \$/MMBtu		\$0.3																							
NO CHP	Total non-CHP Energy Cost \$/MMBtu		\$3.0																							
RE-CHP																										
w/RE-CHP	Cost of Grid Power \$/MWh		\$0.4																							
w/RE-CHP	Grid power Standby Charges \$/MMBtu		\$0.0																							
w/RE-CHP	Total cost of Grid power \$/MMBtu		\$0.5																							
w/RE-CHP	Cost of Blr natural gas \$/MMBtu		\$0.4																							
w/RE-CHP	Cost of RE natural gas \$/MMBtu		\$0.6																							
w/RE-CHP	Fuel Total: natural gas \$/MMBtu		\$1.0																							
w/RE-CHP	O&M: Boilers \$/MMBtu		\$0.138																							
w/RE-CHP	O&M: RE-CHP \$/MMBtu		\$0.6																							
w/RE-CHP	O&M: Total \$/MMBtu		\$0.8																							
Total RE-CHP Fuel+O&M Cost \$/MMBtu			\$2.2																							
RE-CHP Debt Service																										
Principal \$/MMBtu			\$0.00																							
Interest \$/MMBtu			\$0.00																							
Total Payment \$/MMBtu			\$0.00																							
RE-CHP Cost (Fuel+O&M+Debt Service) \$/MMBtu			\$2.2																							
Savings: RE-CHP Vs. NO CHP \$/MMBtu			\$0.8																							
CUMULATIVE Savings: RE-CHP Vs. NO CHP Multiple of Investment on Equity			0.13																							

CHP BASE CASE: 2 x OPRA GT

Good electrical fit, average thermal fit; economics hurt by high CapEx and OpEx. Lower thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	7.6	assumed
CHP full-load availability	%	97%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	10%	assumed
OPRA Gas Turbine (GT) CHP		OPRA16	
Project term	years	10	
GT-CHP Project Investment	\$/KW _e	\$2,828	CapEx estimate
# of GT-CHP systems		2	as configured
Iso Power	KW _e	1,750	3500 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	12	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical

OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	GT-CHP	
Project Financing Structure					
100%	Equity	\$MM	-	\$9.9	
0%	Debt	\$MM	-	\$0.0	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$9.9	
Site Energy Expense in Year 1					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$3.0	\$2.2	\$0.8
Site Energy Expense over Project term 10 years					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$31.1	\$22.9	\$8.2
	Multiple of Investment on Equity		-	0.8	
HHV Thermodynamic Metrics					
	Efficiency	%	-	60%	
	Electrical Heat Rate	MMBtu/MWh	-	8.9	
	Thermal Energy Rate	MMBtu/MMBtu _{th}	-	1.5	
	CHP Thermal Utilization	%	-	64%	









CHP BASE CASE: 1 x Centaur 40 GT

Good technical fit; economics hurt by high CapEx and assumed high grid standby charge. Higher thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	7.6	assumed
CHP full-load availability	%	95%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	20%	assumed
OPRA Gas Turbine (GT) CHP		Centaur40	
Project term	years	10	
GT-CHP Project Investment	\$/KW _e	\$2,918	CapEx estimate
# of GT-CHP systems		1	as configured
Iso Power	KW _e	3,159	3159 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	12	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical

OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	GT-CHP	
Project Financing Structure					
100%	Equity	\$MM	-	\$9.2	
0%	Debt	\$MM	-	\$0.0	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$9.2	
Site Energy Expense in Year 1					
Grid Pwr + fuel + OpEx + Debt Service		\$MM	\$3.0	\$2.0	\$1.1
Site Energy Expense over Project term 10 years					
Grid Pwr + fuel + OpEx + Debt Service		\$MM	\$31.1	\$20.4	\$10.7
Multiple of Investment on Equity			-	1.2	
HHV Thermodynamic Metrics					
Efficiency		%	-	63%	
Electrical Heat Rate		MMBtu/MWh	-	8.3	
Thermal Energy Rate		MMBtu/MMBtu _{th}	-	1.3	
CHP Thermal Utilization		%	-	77%	







CHP BASE CASE: 2 x JMS420 RE

Good electrical fit; average thermal fit. Economics helped by low CapEx but hurt by high OpEx including 60,000 major overhauls (“spiky”). CHP efficiency low due to wasted low-grade thermal energy (hot water). Lower thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	7.6	assumed
CHP full-load availability	%	95%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	10%	assumed
Reciprocating Internal Combustion Engine (RE) CHP		JMS420	
Project term	years	10	
RE-CHP Project Investment	\$/KW _e	\$2,051	CapEx estimate
# of RE-CHP systems		2	as configured
Iso Power	KW _e	1,429	2858 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	12	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical

OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	RE-CHP	
Project Financing Structure					
100%	Equity	\$MM	-	\$5.9	
0%	Debt	\$MM	-	\$0.0	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$5.9	
Site Energy Expense in Year 1					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$3.0	\$2.2	\$0.8
Site Energy Expense over Project term 10 years					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$31.1	\$24.4	\$6.7
	Multiple of Investment on Equity		-	1.1	
HHV Thermodynamic Metrics					
	Efficiency	%	-	61%	
	Electrical Heat Rate	MMBtu/MWh	-	6.8	
	Thermal Energy Rate	MMBtu/MMBtu _{th}	-	2.9	
	CHP Thermal Utilization	%	-	63%	





Alternate scenario: Base Case (100% equity) and CHP project horizon 15-years & 20-years

COMMON INPUT's	UNIT	VALUE	COMMENT
FUTURE baseline site Load	% load increase	50%	2020 base
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price	c/KWh	7.6	site data
CHP project financing			
CHP Project horizon (max 20-yrs)	years	15	
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	10	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	assumed

	NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover	-	JMS420	OPRA16	Centaur40
CHP Configuration	Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40

*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)	-	-	1.8	1.2	1.7
***Site Energy Expense					
Year 1	\$MM	\$3.0	\$2.2	\$2.2	\$2.0
Year 15	\$MM	\$47	\$37	\$35	\$31
Cum. %redn. 15 yrs	% reduction	0%	-22%	-26%	-34%

Emissions					
From grid power	mt CO ₂	22,184	4,641	1,652	3,246
From fuel to Blrs	mt CO ₂	10,264	6,987	360	699
From fuel to CHP	mt CO ₂	-	11,004	21,434	19,395
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446	23,340
Emissions reduction	% change	0%	-30%	-28%	-28%

CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	61.3%	60.4%	63.4%
Thermal Utilization	%	-	63%	64%	77%

Annual Energy supply to site					
Fuel to Blrs	MMBtu	193,164	131,494	6,769	13,161
Fuel to CHP	MMBtu	-	207,094	403,375	365,005
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144	378,166

Elec. From grid	MWh	28,093	5,877	2,093	4,110
Elec. From CHP	MWh	-	22,215	26,000	23,982
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093	28,093

COMMON INPUT's	UNIT	VALUE	COMMENT
FUTURE baseline site Load	% load increase	50%	2020 base
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price	c/KWh	7.6	site data
CHP project financing			
CHP Project horizon (max 20-yrs)	years	20	
Equity:Debt Ratio	%	100%	assumed
Debt Term	years	10	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	assumed

	NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover	-	JMS420	OPRA16	Centaur40
CHP Configuration	Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40

*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)	-	-	2.2	1.6	2.3
***Site Energy Expense					
Year 1	\$MM	\$3.0	\$2.2	\$2.2	\$2.0
Year 20	\$MM	\$64	\$51	\$48	\$42
Cum. %redn. 20 yrs	% reduction	0%	-20%	-25%	-33%

Emissions					
From grid power	mt CO ₂	22,184	4,641	1,652	3,246
From fuel to Blrs	mt CO ₂	10,264	6,987	360	699
From fuel to CHP	mt CO ₂	-	11,004	21,434	19,395
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446	23,340
Emissions reduction	% change	0%	-30%	-28%	-28%

CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	61.3%	60.4%	63.4%
Thermal Utilization	%	-	63%	64%	77%

Annual Energy supply to site					
Fuel to Blrs	MMBtu	193,164	131,494	6,769	13,161
Fuel to CHP	MMBtu	-	207,094	403,375	365,005
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144	378,166

Elec. From grid	MWh	28,093	5,877	2,093	4,110
Elec. From CHP	MWh	-	22,215	26,000	23,982
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093	28,093



Alternate scenario: base case (100% equity) with 25% and 75% future site load increases

COMMON INPUT's			UNIT	VALUE	COMMENT
FUTURE baseline site Load			% load increase	25%	2020 base
Natural Gas at "Burner tip"			\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price			c/KWh	7.6	site data
CHP project financing					
CHP Project horizon (max 20-yr)			years	10	
Equity:Debt Ratio			%	100%	assumed
Debt Term			years	10	assumed
Cost of Debt			%	7%	assumed
Pre-CHP Package Boiler					
Displaced package boiler efficiency			% HHV	83%	site data
Package Boiler: Variable Charge/cost			cents/MMBtu _{th}	125	assumed

			NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover			-	JMS420	OPRA16	Centaur40
CHP Configuration			Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-		\$5.9	\$9.9	\$9.2
	\$/KW _e	-		\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-		\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)		-		1.0	0.6	1.0
***Site Energy Expense						
Year 1	\$MM	\$2.5		\$1.8	\$1.9	\$1.7
Year 10	\$MM	\$26		\$20	\$20	\$17
Cum. %redn. 10 yrs	% reduction	0%		-23%	-22%	-34%
Emissions						
From grid power	mt CO ₂	18,487		1,891	632	1,285
From fuel to Blrs	mt CO ₂	8,553		5,576	280	537
From fuel to CHP	mt CO ₂	-		10,445	19,093	18,053
TOTAL site emissions	mt CO ₂	27,040		17,912	20,005	19,875
Emissions reduction	% change	0%		-34%	-26%	-26%
CHP technical						
CHP capacity	KW _e	-		2,858	3,500	3,159
CHP efficiency	% HHV	-		60.2%	57.4%	58.7%
Thermal Utilization	%			61%	61%	71%
Annual Energy supply to site						
Fuel to Blrs	MMBtu	160,970		104,937	5,264	10,108
Fuel to CHP	MMBtu	-		196,563	359,330	339,751
TOTAL Fuel (CHP + Blrs)	MMBtu	160,970		301,500	364,594	349,859
Elec. From grid	MWh	23,411		2,395	801	1,627
Elec. From CHP	MWh	-		21,016	22,610	21,783
TOTAL Elec. (CHP + grid)	MWh	23,411		23,411	23,411	23,411

COMMON INPUT's			UNIT	VALUE	COMMENT
FUTURE baseline site Load			% load increase	75%	2020 base
Natural Gas at "Burner tip"			\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price			c/KWh	7.6	site data
CHP project financing					
CHP Project horizon (max 20-yr's)			years	10	
Equity:Debt Ratio			%	100%	assumed
Debt Term			years	10	assumed
Cost of Debt			%	7%	assumed
Pre-CHP Package Boiler					
Displaced package boiler efficiency			% HHV	83%	site data
Package Boiler: Variable Charge/cost			cents/MMBtu _{th}	125	assumed
NO CHP			Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover			JMS420	OPRA16	Centaur40
CHP Configuration			2 x JMS420	2 x OPRA16	1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)		-	1.2	1.0	1.2
***Site Energy Expense					
Year 1	\$MM	\$3.5	\$2.7	\$2.5	\$2.4
Year 10	\$MM	\$36	\$29	\$26	\$25
Cum. %redn. 10 yrs	% reduction	0%	-19%	-27%	-32%
Emissions					
From grid power	mt CO ₂	25,882	7,961	4,161	6,320
From fuel to Blrs	mt CO ₂	11,975	8,483	441	1,194
From fuel to CHP	mt CO ₂	-	11,224	22,522	19,870
TOTAL site emissions	mt CO ₂	37,856	27,668	27,124	27,384
Emissions reduction	% change	0%	-27%	-28%	-28%
CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	62.5%	64.7%	67.6%
Thermal Utilization	%		66%	70%	85%
Annual Energy supply to site					
Fuel to Blrs	MMBtu	225,358	159,644	8,296	22,472
Fuel to CHP	MMBtu	-	211,233	423,852	373,952
TOTAL Fuel (CHP + Blrs)	MMBtu	225,358	370,877	432,149	396,424
Elec. From grid	MWh	32,775	10,081	5,269	8,003
Elec. From CHP	MWh	-	22,693	27,506	24,772
TOTAL Elec. (CHP + grid)	MWh	32,775	32,775	32,775	32,775



Alternate scenario: financial leverage (25% equity) boosts MOI. CHP: 10-years and 20-years

COMMON INPUT's		UNIT	VALUE	COMMENT
FUTURE baseline site Load		% load increase	50%	2020 base
Natural Gas at "Burner tip"		\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price		c/KWh	7.6	site data
CHP project financing				
CHP Project horizon (max 20-yrs)		years	10	
Equity:Debt Ratio		%	25%	assumed
Debt Term		years	7	assumed
Cost of Debt		%	7%	assumed
Pre-CHP Package Boiler				
Displaced package boiler efficiency		% HHV	83%	site data
Package Boiler: Variable Charge/cost		cents/MMBtu _{th}	125	assumed
	NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover	-	JMS420	OPRA16	Centaur40
CHP Configuration	Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9
	\$/KW _e	-	\$2,051	\$2,828
of which Equity reqd.	\$MM	-	\$1.5	\$2.5
**Equity-Multiple of Investment (MOI)	-	-	0.7	(0.6)
***Site Energy Expense				
Year 1	\$MM	\$3.0	\$3.1	\$3.6
Year 10	\$MM	\$31	\$30	\$32
Cum. %redn. 10 yrs	% reduction	0%	-3%	5%
Emissions				
From grid power	mt CO ₂	22,184	4,641	1,652
From fuel to Blrs	mt CO ₂	10,264	6,987	360
From fuel to CHP	mt CO ₂	-	11,004	21,434
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446
Emissions reduction	% change	0%	-30%	-28%
CHP technical				
CHP capacity	KW _e	-	2,858	3,500
CHP efficiency	% HHV	-	61.3%	60.4%
Thermal Utilization	%	-	63%	64%
Annual Energy supply to site				
Fuel to Blrs	MMBtu	193,164	131,494	6,769
Fuel to CHP	MMBtu	-	207,094	403,375
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144
Elec. From grid	MWh	28,093	5,877	2,093
Elec. From CHP	MWh	-	22,215	26,000
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093

COMMON INPUT's		UNIT	VALUE	COMMENT
FUTURE baseline site Load		% load increase	50%	2020 base
Natural Gas at "Burner tip"		\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price		c/KWh	7.6	site data
CHP project financing				
CHP Project horizon (max 20-yrs)		years	20	
Equity:Debt Ratio		%	25%	assumed
Debt Term		years	7	assumed
Cost of Debt		%	7%	assumed
Pre-CHP Package Boiler				
Displaced package boiler efficiency		% HHV	83%	site data
Package Boiler: Variable Charge/cost		cents/MMBtu _{th}	125	assumed
	NO CHP	Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover	-	JMS420	OPRA16	Centaur40
CHP Configuration	Grid + Blrs only	2 x JMS420	2 x OPRA16	1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9
	\$/KW _e	-	\$2,051	\$2,828
of which Equity reqd.	\$MM	-	\$1.5	\$2.5
**Equity-Multiple of Investment (MOI)	-	-	4.8	2.5
***Site Energy Expense				
Year 1	\$MM	\$3.0	\$3.1	\$3.6
Year 20	\$MM	\$64	\$57	\$58
Cum. %redn. 20 yrs	% reduction	0%	-11%	-10%
Emissions				
From grid power	mt CO ₂	22,184	4,641	1,652
From fuel to Blrs	mt CO ₂	10,264	6,987	360
From fuel to CHP	mt CO ₂	-	11,004	21,434
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446
Emissions reduction	% change	0%	-30%	-28%
CHP technical				
CHP capacity	KW _e	-	2,858	3,500
CHP efficiency	% HHV	-	61.3%	60.4%
Thermal Utilization	%	-	63%	64%
Annual Energy supply to site				
Fuel to Blrs	MMBtu	193,164	131,494	6,769
Fuel to CHP	MMBtu	-	207,094	403,375
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144
Elec. From grid	MWh	28,093	5,877	2,093
Elec. From CHP	MWh	-	22,215	26,000
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093



Other scenarios? Eg: higher grid price increases MOI; leverage & CHP years turbocharge MOI.

COMMON INPUT's			UNIT	VALUE	COMMENT
FUTURE baseline site Load			% load increase	50%	2020 base
Natural Gas at "Burner tip"			\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price			c/KWh	10.0	site data
CHP project financing					
CHP Project horizon (max 20-yr)			years	10	
Equity:Debt Ratio			%	100%	assumed
Debt Term			years	7	assumed
Cost of Debt			%	7%	assumed
Pre-CHP Package Boiler					
Displaced package boiler efficiency			% HHV	83%	site data
Package Boiler: Variable Charge/cost			cents/MMBtu _{th}	125	assumed
NO CHP			Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover			-	JMS420	OPRA16
CHP Configuration			Grid + Blrs only	2 x JMS420	2 x OPRA16
					1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$5.9	\$9.9	\$9.2
**Equity-Multiple of Investment (MOI)		-	2.1	1.5	1.8
***Site Energy Expense					
Year 1	\$MM	\$3.7	\$2.4	\$2.2	\$2.1
Year 10	\$MM	\$38	\$26	\$23	\$22
Cum. %redn. 10 yrs	% reduction	0%	-32%	-38%	-43%
Emissions					
From grid power	mt CO ₂	22,184	4,641	1,652	3,246
From fuel to Blrs	mt CO ₂	10,264	6,987	360	699
From fuel to CHP	mt CO ₂	-	11,004	21,434	19,395
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446	23,340
Emissions reduction	% change	0%	-30%	-28%	-28%
CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	61.3%	60.4%	63.4%
Thermal Utilization	%		63%	64%	77%
Annual Energy supply to site					
Fuel to Blrs	MMBtu	193,164	131,494	6,769	13,161
Fuel to CHP	MMBtu	-	207,094	403,375	365,005
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144	378,166
Elec. From grid	MWh	28,093	5,877	2,093	4,110
Elec. From CHP	MWh	-	22,215	26,000	23,982
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093	28,093

COMMON INPUT's			UNIT	VALUE	COMMENT
FUTURE baseline site Load			% load increase	50%	2020 base
Natural Gas at "Burner tip"			\$/MMBtu, HHV	\$2.76	site data
All-in Grid power price			c/KWh	10.0	site data
CHP project financing					
CHP Project horizon (max 20-yr)			years	20	
Equity:Debt Ratio			%	25%	assumed
Debt Term			years	7	assumed
Cost of Debt			%	7%	assumed
Pre-CHP Package Boiler					
Displaced package boiler efficiency			% HHV	83%	site data
Package Boiler: Variable Charge/cost			cents/MMBtu _{th}	125	assumed
NO CHP			Recip. Engine	Gas Turbine	Gas Turbine
CHP Prime Mover			-	JMS420	OPRA16
CHP Configuration			Grid + Blrs only	2 x JMS420	2 x OPRA16
					1 x Centaur40
*Pjt. Inv. w/10% ITC	\$MM	-	\$5.9	\$9.9	\$9.2
	\$/KW _e	-	\$2,051	\$2,828	\$2,918
of which Equity reqd.	\$MM	-	\$1.5	\$2.5	\$2.3
**Equity-Multiple of Investment (MOI)		-	12.3	7.8	10.5
***Site Energy Expense					
Year 1	\$MM	\$3.7	\$3.2	\$3.6	\$3.4
Year 20	\$MM	\$78	\$60	\$59	\$54
Cum. %redn. 20 yrs	% reduction	0%	-23%	-25%	-31%
Emissions					
From grid power	mt CO ₂	22,184	4,641	1,652	3,246
From fuel to Blrs	mt CO ₂	10,264	6,987	360	699
From fuel to CHP	mt CO ₂	-	11,004	21,434	19,395
TOTAL site emissions	mt CO ₂	32,448	22,633	23,446	23,340
Emissions reduction	% change	0%	-30%	-28%	-28%
CHP technical					
CHP capacity	KW _e	-	2,858	3,500	3,159
CHP efficiency	% HHV	-	61.3%	60.4%	63.4%
Thermal Utilization	%		63%	64%	77%
Annual Energy supply to site					
Fuel to Blrs	MMBtu	193,164	131,494	6,769	13,161
Fuel to CHP	MMBtu	-	207,094	403,375	365,005
TOTAL Fuel (CHP + Blrs)	MMBtu	193,164	338,587	410,144	378,166
Elec. From grid	MWh	28,093	5,877	2,093	4,110
Elec. From CHP	MWh	-	22,215	26,000	23,982
TOTAL Elec. (CHP + grid)	MWh	28,093	28,093	28,093	28,093







2 x OPRA GT ideal upside: leverage (25% equity), high grid power (10 cents/KWh) and CHP 20-years

Good electrical fit, average thermal fit; economics hurt by high CapEx and OpEx. Lower thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	10.0	assumed
CHP full-load availability	%	97%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	10%	assumed
OPRA Gas Turbine (GT) CHP		OPRA16	
Project term	years	20	
GT-CHP Project Investment	\$/KW _e	\$2,828	CapEx estimate
# of GT-CHP systems		2	as configured
Iso Power	KW _e	1,750	3500 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	25%	assumed
Debt Term	years	7	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical

OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	GT-CHP	
Project Financing Structure					
25%	Equity	\$MM	-	\$2.5	
75%	Debt	\$MM	-	\$7.4	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$9.9	
Site Energy Expense in Year 1					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$3.7	\$3.6	\$0.1
Site Energy Expense over Project term 20 years					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$78.0	\$58.7	\$19.3
	Multiple of Investment on Equity		-	7.8	
HHV Thermodynamic Metrics					
	Efficiency	%	-	60%	
	Electrical Heat Rate	MMBtu/MWh	-	8.9	
	Thermal Energy Rate	MMBtu/MMBtu _{th}	-	1.5	
	CHP Thermal Utilization	%	-	64%	







1 x Centaur40 GT ideal upside: leverage (25% equity), high grid power (10 cents/KWh) and CHP 20-years

Good technical fit; economics hurt by high CapEx and assumed high grid standby charge. Higher thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	10.0	assumed
CHP full-load availability	%	95%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	20%	assumed
OPRA Gas Turbine (GT) CHP		Centaur40	
Project term	years	20	
GT-CHP Project Investment	\$/KW _e	\$2,918	CapEx estimate
# of GT-CHP systems		1	as configured
Iso Power	KW _e	3,159	3159 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	25%	assumed
Debt Term	years	7	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical

OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	GT-CHP	
Project Financing Structure					
25%	Equity	\$MM	-	\$2.3	
75%	Debt	\$MM	-	\$6.9	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$9.2	
Site Energy Expense in Year 1					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$3.7	\$3.4	\$0.3
Site Energy Expense over Project term 20 years					
	Grid Pwr + fuel + OpEx + Debt Service	\$MM	\$78.0	\$54.0	\$24.1
	Multiple of Investment on Equity		-	10.5	
HHV Thermodynamic Metrics					
	Efficiency	%	-	63%	
	Electrical Heat Rate	MMBtu/MWh	-	8.3	
	Thermal Energy Rate	MMBtu/MMBtu _{th}	-	1.3	
	CHP Thermal Utilization	%	-	77%	









2 x JMS420 RE ideal upside: leverage (25% equity), high grid power (10 cents/KWh) and CHP 20-years

Good electrical fit; average thermal fit. Economics helped by low CapEx but hurt by high OpEx including 60,000 major overhauls (“spiky”). CHP efficiency low due to wasted low-grade thermal energy (hot water). Lower thermal utilization

INPUT	UNIT	VALUE	COMMENT
Natural Gas at "Burner tip"	\$/MMBtu, HHV	\$2.76	assumed
All-in Grid power price	c/KWh	10.0	assumed
CHP full-load availability	%	95%	assumed
W/CHP, Grid Standby Charges	% of value of CHP pwr	10%	assumed
Reciprocating Internal Combustion Engine (RE) CHP			
JMS420			
Project term	years	20	
RE-CHP Project Investment	\$/KW _e	\$2,051	CapEx estimate
# of RE-CHP systems		2	as configured
Iso Power	KW _e	1,429	2858 KWe CHP capacity
CHP project financing			
Equity:Debt Ratio	%	25%	assumed
Debt Term	years	7	assumed
Cost of Debt	%	7%	assumed
Pre-CHP Package Boiler			
Displaced package boiler efficiency	% HHV	83%	site data
Package Boiler: Variable Charge/cost	cents/MMBtu _{th}	125	typical









OUTPUT		UNIT	VALUE	VALUE	Difference
			No CHP	RE-CHP	
<u>Project Financing Structure</u>					
25%	Equity	\$MM	-	\$1.5	
75%	Debt	\$MM	-	\$4.4	
100%	CHP only Investment incl. 10% ITC	\$MM	-	\$5.9	
<u>Site Energy Expense in Year 1</u>					
Grid Pwr + fuel + OpEx + Debt Service		\$MM	\$3.7	\$3.2	\$0.5
<u>Site Energy Expense over Project term 20 years</u>					
Grid Pwr + fuel + OpEx + Debt Service		\$MM	\$78.0	\$60.0	\$18.1
Multiple of Investment on Equity			-	12.3	
<u>HHV Thermodynamic Metrics</u>					
Efficiency		%	-	61%	
Electrical Heat Rate		MMBtu/MWh	-	6.8	
Thermal Energy Rate		MMBtu/MMBtu _{th}	-	2.9	
CHP Thermal Utilization		%	-	63%	






Technical Observation: power & thermal loads correlated. Future yr loads 50% > Year 2020 loads





CHP sizing & prime mover selection: Match hourly load (power & thermal energy) to supply









Prime mover (GT, RE) ambient temperature performance curves

Heat Rate Vs. power and Vs % Waste Heat Recovered vs. power estimated from vendor data at ambient conditions.
Winter electrical overperformance balances summer electrical underperformance (especially fir GTs)




OPRA16	Power	HHV HR	HRSG- pinch
% of max pwr	KW	Btu/KWh	% of avail
100%	1,750	15,002	75%
90%	1,575	15,302	2.0% 74%
80%	1,400	15,752	2.9% 73%
70%	1,225	16,352	3.7% 72%
60%	1,050	17,403	6.0% 71%
50%	875	18,603	6.5% 70%
40%	700	20,658	9.9% 69%
30%	525	23,628	12.6% 68%












Centaur40	Power	HHV HR	HRSG- pinch
% of max pwr	KW	Btu/KWh	% of avail WH
100%	3,159	14,695	52.9%
90%	2,843	15,050	2.4% 51.8%
80%	2,527	15,542	3.3% 52.4%
70%	2,211	16,457	5.9% 53.0%
60%	1,895	17,726	7.7% 53.6%
50%	1,580	19,398	9.4% 54.1%
40%	1,264	21,250	9.5% 55.1%
30%	948	23,300	9.6% 59.7%



JMS420	Power	HHV HR	RE-HRSG- pinch	Jkt HW
% of max pwr	KW	Btu/KWh	% of avail	% of avail
100%	1,429	9,175	24.0%	36.0%
90%	1,286	9,266	1.0% 23.8%	35.8%
80%	1,143	9,358	1.0% 23.5%	35.5%
70%	1,000	9,450	1.0% 23.3%	35.3%
60%	857	9,725	2.8% 23.0%	35.0%
50%	715	10,000	2.8% 22.8%	34.8%
40%	572	10,471	4.5% 22.5%	34.5%
30%	429	10,762	2.7% 22.3%	34.3%



Technical characteristics: ponder CHP efficiency, wasted heat and power capacity



IMPORTANT: CHP Efficiency will exceed calculated efficiency shown if CHP scheduled maintenance can coincide with plant annual 2-weeks shutdown; hence excluding period of low load and hence low CHP efficiency



Selection metrics? Change in fuel, capacity, GHG reduction, CapEx (next few slides)

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# GTs	2	OPRA16		
Each GT nominal power	KW _e	1,750	3500 KWe CHP capacity		
GT-CHP annual availability	%	97%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	2,093		
Elec. from CHP	MWh	0	26,000		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	5,618		
CHP Thermal (HRSG)	MMBtu	0	154,707		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	6,769		
Fuel to CHP	MMBtu	0	403,375		
TOT. Fuel	MMBtu	193,164	410,144	216,980	112%
CO2 Emissions: grid	MT CO ₂	22,184	1,652		
CO2 Emissions: fuel	MT CO ₂	10,264	21,794		
CO2 TOTAL emissions	MT CO ₂	32,448	23,446	(9,002)	-28%
Overall CHP Efficiency	% HHV		60%		
CHP Thermal Utilization	%		64%		
Full-scope maintenance					
INPUTS	2 x OPRA16	COMMENT			
Fired Hrs/yr	8,497				
\$/fired.hr	\$35.00	Internal Est.			
RESULTS	2 x OPRA16				
MWh/yr	26,000				
\$/MWh	\$22.9				
cents/KWh	2.29				
\$K/yr	\$594,804				

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# GTs	1	Centaur40		
Each GT power at site cdns	KW _e	3,159	3159 KWe CHP capacity		
GT-CHP annual availability	%	95%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	4,110		
Elec. from CHP	MWh	0	23,982		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	10,923		
CHP Thermal (HRSG)	MMBtu	0	149,403		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	13,161		
Fuel to CHP	MMBtu	0	365,005		
TOT. Fuel	MMBtu	193,164	378,166	185,002	96%
CO2 Emissions: grid	MT CO ₂	22,184	3,246		
CO2 Emissions: fuel	MT CO ₂	10,264	20,094		
CO2 TOTAL emissions	MT CO ₂	32,448	23,340	(9,108)	-28%
Overall CHP Efficiency	% HHV		63%		
CHP Thermal Utilization	%		77%		
Full-scope maintenance					
INPUTS	1 x Centaur40	COMMENT			
Fired Hrs/yr	8,322				
\$/fired.hr	\$32.00	5-18-2021 call/Kevin Jensen			
RESULTS	1 x Centaur40				
MWh/yr	23,982				
\$/MWh	\$11.1				
cents/KWh	1.11				
\$K/yr	\$266,304				

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# RES	2	JMS420		
Each RE nominal power	KW _e	1,429	2858 KWe CHP capacity		
RE-CHP annual availability	%	95%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	5,877		
Elec. from CHP	MWh	0	22,215		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	109,140		
CHP Thermal (HRSG, Jkt HW)	MMBtu	0	51,186		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	131,494		
Fuel to CHP	MMBtu	0	207,094		
TOT. Fuel	MMBtu	193,164	338,587	145,424	75%
CO2 Emissions: grid	MT CO ₂	22,184	4,641		
CO2 Emissions: fuel	MT CO ₂	10,264	17,991		
CO2 TOTAL emissions	MT CO ₂	32,448	22,633	(9,816)	-30%
Overall CHP Efficiency	% HHV		61%		
CHP Thermal Utilization	%		63%		
Full-scope maintenance					
INPUTS	2 x JMS420	COMMENT			
Fired Hrs/yr	8,322				
\$/fired.hr	\$27.68	per vendor			
RESULTS	2 x JMS420				
MWh/yr	22,215				
\$/MWh	\$20.7				
cents/KWh	2.07				
\$K/yr	\$460,706				

Above maintenance figures exclude additional expense for non-CHP equipment maintenance, consumables and staff

IMPORTANT: CHP Efficiency will exceed calculated efficiency shown if CHP scheduled maintenance can coincide with plant annual 2-weeks shutdown; hence excluding period of low load and hence low CHP efficiency



CHP configuration: 2 x Gas Turbine as OPRA16; slightly increased CHP availability

Cost metric	On/Off		Unit Cost \$MM	Quantity	Extd. Cost \$MM	COMMENT
A. Equipment						
\$1,000	1	Gas Turbine	\$1.75	2	\$3.50	OPRA GT, Elec (Switchgear, MCC, breakers), utility tie-in, Gas Compressor, No DA , HRSG (no duct-burner)
44%		GT-HRSG	\$0.77	2	\$1.54	
18%		Gas Compressor	\$0.32	2	\$0.63	
\$600	0	Reciprocating Engine	\$0.00	2	\$0.00	
25%		RE-HRSG/HRU	\$0.00	2	\$0.00	
		Other	\$0.00	1	\$0.00	
		Sub-total	\$2.84		\$5.67	
B. Balance of Plant (BOP)						
35%		Civil, Mech, Electrical, I&C etc..	\$0.99	1	\$0.99	SJ est.; edit after FEL3
14%		Eqpmt x'port to site, unload & siting	\$0.40	1	\$0.40	SJ est.; edit after FEL3
		Other	\$0.00	1	\$0.00	
		Sub-total	\$1.39		\$1.39	
C. Indirect ("Soft") costs						
20%		Engg, PM/CM	\$0.84	1	\$0.84	ST budgetary; edit after FEL3
8%		Legal/Env. & permitting	\$0.34	1	\$0.34	SJ est.; edit after FEL3
3%		Bonding, Insurance	\$0.13	1	\$0.13	SJ est.; edit after FEL3
30%		Financing, Wkg Cpts, Devp. Fee etc...	\$1.27	1	\$1.27	SJ est.; edit after FEL3
		Other	\$0.00	1	\$0.00	
		Sub-total	\$2.58		\$2.58	
20%		D. Contingency	\$1.36	1	\$1.36	missing scope items
		E. CHP ONLY INVESTMENT	\$8.16		\$11.00	\$3142 /KW
1		F. 10% Investment Tax Credit (ITC)			(\$1.10)	ITC applies to CHP investment
		G. CHP ONLY INVESTMENT including 10% ITC			\$9.90	\$2828 /KW
Cost, \$MM	On/Off	NON-CHP CAPEX ADDs & OFFSETS			\$MM	COMMENT
\$2.00	0	Site upgrade: electrical infrastructure			\$0.00	Host to add / delete specific non-CHP CapEx line items per host analysis of resiliency (redunancy + availability) required
\$1.00	0	New package boiler			\$0.00	
\$0.90	0	Diesel b/u (Gen-set, fuel tank, pump skid)			\$0.00	
\$0.35	0	Onsite propane fuel tank + fuel pump skid			\$0.00	
\$0.00	0	other			\$0.00	
\$0.00	0	Other			\$0.00	
		H. SUB-TOTAL			\$0.00	\$0 /KW
		I. OVERALL PROJECT INVESTMENT			\$9.90	\$2828 /KW

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# GTs	2	OPRA16		
Each GT nominal power	KW _e	1,750	3500 KWe CHP capacity		
GT-CHP annual availability	%	97%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	2,093		
Elec. from CHP	MWh	0	26,000		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	5,618		
CHP Thermal (HRSG)	MMBtu	0	154,707		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	6,769		
Fuel to CHP	MMBtu	0	403,375		
TOT. Fuel	MMBtu	193,164	410,144	216,980	112%
CO2 Emissions: grid	MT CO ₂	22,184	1,652		
CO2 Emissions: fuel	MT CO ₂	10,264	21,794		
CO2 TOTAL emissions	MT CO ₂	32,448	23,446	(9,002)	-28%
Overall CHP Efficiency	% HHV		60%		
CHP Thermal Utilization	%		64%		
Full-scope maintenance					
INPUTS	2 x OPRA16	COMMENT			
Fired Hrs/yr	8,497				
\$/fired.hr	\$35.00	Internal Est.			
RESULTS	2 x OPRA16				
MWh/yr	26,000				
\$/MWh	\$22.9				
cents/KWh	2.29				
\$K/yr	\$594,804				

Several small GT choices available and OPRA16 is indicative selection only



CHP configuration: 1 x Gas Turbine as Centaur40

Cost metric	On/Off		Unit Cost \$MM	Quantity	Extd. Cost \$MM	COMMENT
A. Equipment						
\$917	1	Gas Turbine	\$2.90	1	\$2.90	C40 GT, Elec (Switchgear, MCC, breakers), utility tie-in, Gas Compressor, No DA , HRSG (no duct-burner)
45%		GT-HRSG	\$1.30	1	\$1.30	
23%		Gas Compressor	\$0.67	1	\$0.67	
\$600	0	Reciprocating Engine	\$0.00	1	\$0.00	
25%		RE-HRSG/HRU	\$0.00	1	\$0.00	
		Other	\$0.00	1	\$0.00	
		Sub-total	\$4.87		\$4.87	
B. Balance of Plant (BOP)						
20%		Civil, Mech, Electrical, I&C etc..	\$0.97	1	\$0.97	ST budgetary; edit after FEL3
8%		Eqpmt x'port to site, unload & siting	\$0.39	1	\$0.39	ST budgetary; edit after FEL3
		Other	\$0.00	1	\$0.00	
		Sub-total	\$1.36		\$1.36	
C. Indirect ("Soft") costs						
10%		Engg, PM/CM	\$0.62	1	\$0.62	ST budgetary; edit after FEL3
5%		Legal/Env. & permitting	\$0.31	1	\$0.31	SJ est.; edit after FEL3
2%		Bonding, Insurance	\$0.12	1	\$0.12	SJ est.; edit after FEL3
20%		Financing, Wkg Cpts, Devp. Fee etc...	\$1.25	1	\$1.25	SJ est.; edit after FEL3
		Other	\$0.00	1	\$0.00	
		Sub-total	\$2.30		\$2.30	
20%		D. Contingency	\$1.71	1	\$1.71	missing scope items
		E. CHP ONLY INVESTMENT	\$10.24		\$10.24	\$3242 /KW
1		F. 10% Investment Tax Credit (ITC)			(\$1.02)	ITC applies to CHP investment
		G. CHP ONLY INVESTMENT including 10% ITC			\$9.22	\$2918 /KW
Cost, \$MM	On/Off	NON-CHP CAPEX ADDs & OFFSETS			\$MM	COMMENT
\$2.00	0	Site upgrade: electrical infrastructure			\$0.00	
\$1.00	0	New package boiler			\$0.00	
\$0.90	0	Diesel b/u (Gen-set, fuel tank, pump skid)			\$0.00	Host to add / delete specific non-CHP CapEx line items per host analysis of resiliency (redunancy + availability) required
\$0.35	0	Onsite propane fuel tank + fuel pump skid			\$0.00	
\$0.00	0	other			\$0.00	
\$0.00	0	Other			\$0.00	
		H. SUB-TOTAL			\$0.00	\$0 /KW
		I. OVERALL PROJECT INVESTMENT			\$9.22	\$2918 /KW

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# GTs	1	Centaur40		
Each GT power at site cdns	KW _e	3,159	3159 KWe CHP capacity		
GT-CHP annual availability	%	95%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	4,110		
Elec. from CHP	MWh	0	23,982		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	10,923		
CHP Thermal (HRSG)	MMBtu	0	149,403		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	13,161		
Fuel to CHP	MMBtu	0	365,005		
TOT. Fuel	MMBtu	193,164	378,166	185,002	96%
CO2 Emissions: grid	MT CO ₂	22,184	3,246		
CO2 Emissions: fuel	MT CO ₂	10,264	20,094		
CO2 TOTAL emissions	MT CO ₂	32,448	23,340	(9,108)	-28%
Overall CHP Efficiency	% HHV		63%		
CHP Thermal Utilization	%		77%		
Full-scope maintenance					
INPUTS	1 x Centaur40	COMMENT			
Fired Hrs/yr	8,322				
\$/fired.hr	\$32.00	5-18-2021 call/Kevin Jensen			
RESULTS	1 x Centaur40				
MWh/yr	23,982				
\$/MWh	\$11.1				
cents/KWh	1.11				
\$K/yr	\$266,304				

Several small GT choices available and Centaur40 is indicative selection only



CHP configuration: 2 x Reciprocating Engine as JMS420 / 1429 KW

Cost metric	On/Off		\$MM		\$MM	
A. Equipment						
\$750	0	Gas Turbine	\$0.00	2	\$0.00	Enclosure, Fuel gas train, LV alternator, Gen. Circ. Brkr, HW HXs, HRSG, , SCR system, SCADA system, deliv. To site, Installation assistance, commissioning & FAT, O&M manual & dwgs etc...
25%		RE-HRSG	\$0.00	2	\$0.00	
0%		Gas Compressor	\$0.00	2	\$0.00	
\$1,025	1	Reciprocating Engine	\$1.46	2	\$2.93	
0%		RE-HRSG/HRU	\$0.00	2	\$0.00	
		Other	\$0.00	1	\$0.00	
		Sub-total	\$1.46		\$2.93	
B. Balance of Plant (BOP)						
50%		Civil, Mech, Electrical, I&C etc..	\$0.73	1	\$0.73	SJ est.; edit after FEL3
20%		Eqpmt x'port to site, unload & siting other	\$0.29	1	\$0.29	SJ est.; edit after FEL3
			\$0.00	1	\$0.00	
		Sub-total	\$1.03		\$1.03	
C. Indirect ("Soft") costs						
25%		Engg, PM/CM	\$0.62	1	\$0.62	SJ est.; edit after FEL3
10%		Legal/Env. & permitting	\$0.25	1	\$0.25	SJ est.; edit after FEL3
4%		Bonding, Insurance	\$0.10	1	\$0.10	SJ est.; edit after FEL3
30%		Financing, Wkg Cptl, Devp. Fee etc...	\$0.75	1	\$0.75	SJ est.; edit after FEL3
		Other	\$0.00	1	\$0.00	
		Sub-total	\$1.72		\$1.72	
20%		D. Contingency	\$0.84	1	\$0.84	missing scope items
		E. CHP ONLY INVESTMENT	\$5.05		\$6.51	\$2279 /KW
1		F. 10% Investment Tax Credit (ITC)			(\$0.65)	ITC applies to CHP investment
		G. CHP ONLY INVESTMENT including 10% ITC			\$5.86	\$2051 /KW
Cost, \$MM	On/Off	NON-CHP CAPEX ADDs & OFFSETS		\$MM	COMMENT	
\$2.00	0	Site upgrade: electrical infrastructure		\$0.00		
\$1.00	0	New package boiler		\$0.00		
\$0.90	0	Diesel b/u (Gen-set, fuel tank, pump skid)		\$0.00		
\$0.35	0	Onsite propane fuel tank + fuel pump skid		\$0.00		
\$0.00	0	other		\$0.00		Host to add / delete specific non-CHP CapEx line items per host analysis of resiliency (redunancy + availability) required
\$0.00	0	Other		\$0.00		
		H. SUB-TOTAL		\$0.00	\$0 /KW	
		I. OVERALL PROJECT INVESTMENT		\$5.86	\$2051 /KW	

INPUT	UNIT	VALUE	COMMENT		
FUTURE baseline site Load	% load increase	50%	2020 base year		
CHP Configuration	# REs	2	JMS420		
Each RE nominal power	KW _e	1,429	2858 KWe CHP capacity		
RE-CHP annual availability	%	95%			
OUTPUT - ANNUAL	UNIT	No CHP	w/CHP	Change	% change
Elec. from Grid	MWh	28,093	5,877		
Elec. from CHP	MWh	0	22,215		
TOT. Elec.	MWh	28,093	28,093	0	0%
Thermal from Blrs	MMBtu	160,326	109,140		
CHP Thermal (HRSG, Jkt HW)	MMBtu	0	51,186		
TOT. Thermal supply	MMBtu	160,326	160,326	0	0%
Fuel to Blrs	MMBtu	193,164	131,494		
Fuel to CHP	MMBtu	0	207,094		
TOT. Fuel	MMBtu	193,164	338,587	145,424	75%
CO2 Emissions: grid	MT CO ₂	22,184	4,641		
CO2 Emissions: fuel	MT CO ₂	10,264	17,991		
CO2 TOTAL emissions	MT CO ₂	32,448	22,633	(9,816)	-30%
Overall CHP Efficiency	% HHV		61%		
CHP Thermal Utilization	%		63%		
Full-scope maintenance					
INPUTS	2 x JMS420	COMMENT			
Fired Hrs/yr	8,322				
\$/fired.hr	\$27.68	per vendor			
RESULTS	2 x JMS420				
MWh/yr	22,215				
\$/MWh	\$20.7				
cents/KWh	2.07				
\$/K/yr	\$460,706				

Several RE choices available (eg: CAT, MAN, Progen (EMD series)etc.....) and JMS420 is indicative selection only

Present investment proposal to Management; include Project Execution Plan (PEP), key Risks & mitigants, recommend a project financing structure (eg: on-balance sheet, 3rd party financing, other)

If approved, i.e. Limited Notice to Proceed (LNTP),

- Assemble Project team
- Issue RFP to equipment vendors; select engineering firm, owners engineer
- Update financial model; add after-tax cash flows
- Engage local utility (power & gas), community
- Meet with local permitting entities, assess permit pathway & start negotiating permit.
- **Improve project economics by:**
 - Explore selling waste heat to Ind. Facility to the north (*especially for 2 x RE and 2 x GT cases*)
 - Apply for grants & incentives at www.dsireusa.org
 - If available, finance project using **PACE** funds (very long-duration & low-interest). *Repayments are a tax-deductible add-on to site property tax bill.*
 - Negotiate volumetric discount on natural gas delivery charge
 - Factor beneficial economics of avoided investments on electrical infrastructure & thermal (boilers)
 - Explore monetizing greenhouse gas emissions (GHG) reductions

Deliverable & milestone: Final Notice to Proceed (FNTP); begin Equipment procurement, engineering & construction



Stage Gate Process: Front End Loaded (FEL)

FEL STAGE	FEL1: Business Assessment	FEL2: Alternatives Selection. Conceptual Engineering	FEL3: Scope Definition. Basic Engineering	FEL4: Engineering, Procurement & Construction Management (EPCM). Detailed Engineering+	FEL5: Commissioning & Operations & Evaluation
PURPOSE	Identify projects aligned with business objectives	Select preferred process & technology options	Complete scope definiton: validate business premises, ensure project execution with a degree of certainty	Implement Project Execution Plan (PEP)	Meet design nameplate; evaluate against business objectives
OBJECTIVES	Define business premises	Validate business premises	Finalize scope of work, schedule and cost	Complete Detailed Engineering	Achieve nameplate production
	Define project objectives	Analyze alternate process & technology options; select best alternative	Value engineering for cost reduction	Secure required permits	
	List assumptions - technical & commerical	Develop Process scope of work	Mitigation of risks & uncertainties	Create equipment procurement plan	
	Identify risks & state mitigants	Process Flow Diagram with Heat & Mass Balance (PFD + HMB)	Project Execution Plan (PEP)	Mobilize construction resources - project / construction manager, prime contractor & sub-contractors	
	Preliminary economics	Utilities availability ("gap analysis")	Gather project team	EHS management	
	Justify & prioritize projects	Identify uncertainties & risks	Secure project funding	Checkout & commissioning	
DELIVERABLES	FEL 1 deliverables check list	FEL 2 deliverables check list	FEL 3 deliverables check list	Commissioned project	
	Abstract / objectives statement	Basic economic model	Major equipment list & specifications with firm quotes	Purchase & receive equipment & bulk materials, manage construction to support PEP	Collect operating data
	Resource assignment	PFD + HMB, basic plot plan	Finalize plot plan	Manage change orders	Capture formal lessons learned
	Project manager	Permitting requirements & strategy	Issue for design: P&ID, control lists, electrical 1-line diagrams		
	Project Engineer	O&M strategy	Conduct HAZOP review	Final HAZOP review	Capture process improvements for future projects
	Other	EHS requirements & strategy	EHS requirements & strategy		
		Technical risk assessment	Project Execution Plan (PEP) with Work BreakDown Structure (WBS) & sub-contracting plan		Prepare for project close-out
		Major equipment list and key vendors			
	CapEx: Order of magnitude. ± 50%	CapEx: Conceptual estimate +35% -20%	CapEx: quasi-investment grade estimate +15% -5%		
	O&M, G&A: Order of magnitude. ± 50%	O&M, G&A: conceptual estimate. ± 25%	O&M, G&A: estimate ± 15%		
	FEL2 plan with milestone schedule	FEL3 plan with milestone schedule	Detailed construction schedule		
COSTS	\$1,000 <= co\$t <=\$5,000	0.3% <= \$ TIC <= 1.0%	0.7% <= \$ TIC <= 3.0%	3.0% <= \$ Engineering <= 15.0% rest for Procurement & construction	Funded from O&M,G&A budget
FUNDING SOURCE	Owner expensed	Owner expensed	Owner expensed or capitalized	Capitalized	
DURATION	1 <= days <=5	2 <= weeks <=12	6 <= weeks <=18	6 <= months <=24	
GLOSSARY					
O&M, GA	Operations & maintenance, General & Administrative		TIC	Total Installed Cost	
PFD+ HMB	Process Flow Diagram + Heat & Mass Balance		HAZOP	Hazard & Operability Analysis	



Example emissions calculation for permitting & sizing the Emissions Control System (ECS)

INPUT	UNIT	VALUE	VALUE	VALUE	OUTPUT	UNIT	VALUE	VALUE	VALUE	VALUE	VALUE	VALUE		
Exhaust Pollutants		Gas Turbine	HRSG-DB	Pkge Blr						Exit Stack	Exit Stack	Exit Stack		
					Exhaust Pollutants		Gas Turbine	HRSG-DB	CHP total	Poll. Ctrl	HRSG	Pkge Blr	TOTAL SITE	
	NO _x	ppmv	308	33	33	NOx	7.5557849 lb/MMBtu HHV	1.138	0.041	1.179	80% SCR	0.236	0.041	0.277
	CO	ppmv	23	10	30	CO	0.3434448 lb/MMBtu HHV	0.052	0.008	0.059	80% COR	0.012	0.023	0.035
	UHC	ppmv	5	5	5	UHC	lb/MMBtu HHV	0.006	0.002	0.009	-	0.009	0.002	0.011
PM _{2.5}	ppmv	7	7	7	PM2.5	lb/MMBtu HHV	0.014	0.005	0.019	-	0.019	0.005	0.024	
%O2 after GT, hrsg-DB, Blr stack	%	15.0%	3.5%	3.5%	%O2 after GT, hrsg-DB, Blr stack									
Pollutant Properties - Molar Weight														
NOx	lb/lb-mol	46			NOx	lb/hr	58.2	4.1	62.3	80% SCR	12.5	0.5	13	
CO	lb/lb-mol	28			CO	lb/hr	2.6	0.7	3.4	80% COR	0.7	0.3	1	
UHC	lb/lb-mol	16	assumed CH4		UHC	lb/hr	0.3	0.2	0.5	-	0.5	0.0	1	
PM2.5	lb/lb-mol	25	assumed		PM2.5	lb/hr	0.7	0.5	1.2	-	1.2	0.1	1	
Flue Gas properties														
Molar Volume	dscf / lb-mol	379.7	1-atm & 60F		NOx	tons/yr	247.3	17.2	264.5	80% SCR	52.9	2.1	55	OK- NOx 27 % below limit
Fd Factor	dscf / MMBtu	8,608	NG:1050 Btu/scf @60F		CO	tons/yr	11.2	3.2	14.4	80% COR	2.9	1.1	4	OK- CO 84 % below limit
CHP: Effectiveness of Pollution Control component					UHC	tons/yr	1.4	0.9	2.3	-	2.3	0.1	2	OK- UHC 76 % below limit
SCR	only in CHP	80%	assumed		PM2.5	tons/yr	3.1	2.0	5.0	-	5.0	0.2	5	OK- PM2.5 47 % below limit
COR	only in CHP	80%	assumed											
INPUT	UNIT	VALUE	COMMENT	OUTPUT	UNIT	VALUE	VALUE	VALUE	VALUE	VALUE	VALUE			
# of GT- CHP's		1	1 x XYZ CHP			Gas Turbine	HRSG-DB	CHP TOTAL	Pkge Blr	TOTAL SITE				
Each GT power	MW _e	3.5	XYZ	Fuel input	HHV MMBtu/Hr	51	98	149	12	161				
Each GT Heat Rate	LHV MMBtu/MWWh	13.3	XYZ		HHV MMBtu/yr	434,631	833,043	1,267,674	99,629	1,367,303				
Entire Site Steam load	Kpph	125	site data	Steam output	Kpph	19	97	116	9	125				
Pkgr Blr Efficiency	% LHV	86%	site data		MM lb/yr	160	824	984	78	1,062				
Water-to-Steam Enthalpy Gain	MMBtu/Klb	1.1	enter DA, exit Blr	Check: Unfired Steam	Klb/MWWhr			OK	5.4					
Availability (GT-CHP & Pkge Blr)	%	97%	354 days/yr	Check: Steam Rate	HHV MMBtu/ Klb			1.29						
High DF Recov. Factor	% unf. WH Recov.	60%	f(pinch, psig, F)											
DB Marginal Efficiency	% LHV	99%	typical											
Current Permit allowable Emissions														
NOx	tons/yr	75	Assumed	Example output during FEL3 for permitting & scope definition										
CO	tons/yr	25	Assumed											
UHC	tons/yr	10	Assumed											
PM2.5	tons/yr	10	Assumed											

Example output during FEL3 for permitting & scope definition



Questions?

Suresh Jambunathan

630-335-4544

suresh.jambunathan@enwadev.com